

November 27, 2017

Mr. Michael Dominick  
Borough of Ambridge Municipal Authority  
600 Eleventh Street  
Ambridge, PA 15003

Re: Recension of Notices of Violations  
PWSID No. 5040008  
Borough of Ambridge Municipal Authority  
Beaver County

Dear Mr. Dominick:

On October 27, 2016, and February 17, 2017, the Borough of Ambridge Municipal Authority (Authority) was sent Notices of Violation (NOV) for failure to meet Total Organic Compounds (TOC) removal requirements, among other violations. Since that time, the Department has reviewed sample data as submitted for the Authority and determined that Alternate Compliance Criteria was met for TOC removal during all quarters of 2016 and 2017 to date. Consequently, the October 27, 2016, NOV and the portions of the February 17, 2017, NOV which refer to TOC removal requirements have hereby been rescinded.

If you should have any questions regarding any of the information contained herein, please feel free to contact me at the telephone number or address listed below, or via email at [rediehl@pa.gov](mailto:rediehl@pa.gov).

Sincerely,



Renee Diehl  
Environmental Group Manager  
Safe Drinking Water Program

cc: Beaver Falls District Office  
Southwest Regional Office